



**COMMUNITY RISK REDUCTION BUREAU MANUAL  
DEVELOPMENT POLICIES  
425.9 DRIVEWAY, ROADWAY AND ACCESS ROAD TURNING  
RADIUS  
EFFECTIVE: APRIL 1, 2016  
AUTHORIZED: *R. Pearce***

## **SCOPE**

Fire Apparatus access road turning radius.

## **PURPOSE**

The purpose of this policy is to define the minimum required access road turning radius.

## **REQUIREMENTS**

1. The minimum inside turning radius for a driveway serving one or two dwelling units shall be 15 feet.
  - a) In corners and curves with an inside radius less than 60 feet the minimum improved width shall be 14 feet with 16 feet of clearance total.
2. The minimum inside turning radius for an access road serving more than two dwelling units, and all other occupancies, shall be 30 feet.

## **CROSS REFERENCES**

California Fire Code 503.2.4